





#### **State Water Resources Control Board**

Division of Drinking Water

August 18, 2014 Certified Mail/Return 7012 3460 0003 1113 0055

Nuestro School 3934 Broadway Rd. Live Oak. CA 95953

Attention: Joe Hendricks, Principal

Subject: Public Water System No. 5100142 – Citation No. 21-14C-015 for Lead and Copper Rule monitoring violation.

It has come to our attention that the Nuestro School public water system failed to monitor and report lead and copper samples in the year 2013, according to the Lead and Copper Rule (LCR). Consequently, the Division of Drinking Water has issued the enclosed Citation for Noncompliance (Citation) to the water system. The enclosed Citation includes directives for corrective action and public notification.

Section 116577 of the California Safe Drinking Water Act provides for the department to be reimbursed by the public water system for costs incurred for preparing and issuing a citation. The billing rate is \$128 per hour. At this time, we have spent approximately one hour preparing this violation. You will receive a bill for these costs, typically by September 1<sup>st</sup>, from the Sacramento office.

If you have any questions please call Paul Rowe at (530) 224-4866 or contact me directly at (530) 224-4861.

Reese B. Crenshaw, P.E. Valley District Engineer DRINKING WATER FIELD OPERATIONS BRANCH

**Enclosures** 

Citation No. 21-14C-015 1 2 3 STATE OF CALIFORNIA WATER RESOURCES CONTROL BOARD 4 5 6 **Public Water System:** Nuestro School 7 Water System No.: 5100142 8 Nuestro School 9 To: Attn: Joe Hendricks, Principal 10 3934 Broadway Rd. 11 Live Oak, CA 95953 12 13 14 Issued: August 18, 2014 VIA CERTIFIED MAIL 15 16 17 CITATION FOR NONCOMPLIANCE 18 With Title 22 California Code of Regulations, 19 Section 64675 20 21 Section 116650 of the California Health and Safety Code authorizes the issuance of 22 23 a citation to a public water system for violation the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 24 25 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order



26

issued or adopted thereunder.

The State Water Resources Control Board, acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a citation to the California Rehabilitation Center - Norco (hereinafter, CRC) (P.O. Box 1841, Norco, CA 92860-0991) for violation of California Code of Regulations (CCR), Title 22, Section 64533 subsection (a).

### APPLICABLE AUTHORITIES

# Section 116650 of California Health and Safety Code provides:

(a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

19 20

(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.

22

(c) A citation may specify a date for elimination or correction of the condition constituting the violation.

(d) A citation may include the assessment of a penalty as specified in subdivision (e).

26



1	i
2	
3	
4	
5	
6	С
7	p
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19 20	<u>s</u>

(e)	The department may assess a penalty in an amount not to exceed one
	thousand dollars (\$1,000) per day for each day that a violation occurred
	and for each day that a violation continues to occur. A separate penalty may
	be assessed for each violation.

California Code of Regulations, Title 22, Section 64675.5, subsection (a) provides, in relevant part:

- (a) A system shall conduct standard tap sampling for two consecutive periods; thereafter, tap sampling frequency may be reduced pursuant to section 64675 (General Requirements for Tap Sampling for Lead and Copper) as follows:
  - (1) If a system has 90th percentile levels that do not exceed 0.005 mg/L for lead and 0.65 mg/L for copper for two consecutive periods, it may reduce the sampling to once every three years at the reduced number of sites.

# STATEMENT OF FACTS

Nuestro School (hereinafter Water System) is a nontransient-noncommunity water system serving an estimated population of 120 students, faculty, and staff through one connection. The source of supply for the Water System is a groundwater well designated as Well 002 (Source Number 5100142-002).



21

22

23

24

25

CITATION NO. 21-14C-015 Issued: August 18, 2014

Because the Water System meets reduced lead and copper sampling frequency, it is required to collect five (5) lead and copper samples every three years according to Table 64675-A and Section 64675.5 of Title 22. The Water System failed to collect lead and copper samples at the end of the triennial period in 2013. The Division has not received any data to date to indicate that the 2013 or subsequent monitoring was completed. The last samples submitted to the Division were taken in September of 2010.

The Division has determined that the Water System violated Section 64675.5 of the CCR, in that the Water System failed to collect triennial Lead and Copper samples in year 2013.

The Water System is hereby directed to take the following actions:

- 1. Comply with Section 64675.5, Title 22, of the CCR in all future monitoring periods.
- 2. The District has failed to conduct annual lead and copper monitoring from its customer's taps since 2010. This must be completed with the collection of lead and copper samples by September 30, 2014 from five sites. Samples shall be collected in accordance with the Lead and Copper Rule Sampling per Title 22, Section 64677. The analytical results must be reported to the Division by the 10<sup>th</sup> day of the month following the month in which the analyses were completed.



CITATION NO. 21-14C-015 Issued: August 18, 2014

3.	Subseque	nt to dire	ctiv	e #2,	the D	istrict s	shall contir	nue ti	iennial le	ad	and co	ppe
	sampling,	starting	in	the	year	2016	between	the	months	of	June	and
	September.											

4. The District shall provide public notification (by inclusion in the **2014 Consumer Confidence Report**) of the 2013 failure to sample lead and copper, as required by regulations.

All documents required by this Citation to be submitted to the Division shall be submitted to the following address:

Reese B. Crenshaw, P. E.

Valley District Engineer

State Water Resources Control Board

Division of Drinking Water

364 Knollcrest Drive, Suite 101

Redding, CA 96002

(530) 224-4800

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of Health and Safety Code, Division 104, Part 12, Chapter 4 (California Safe Drinking Water Act), or any regulation, permit, standard or order issued or

adopted thereunder.



The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

4

5

6

7

8

9

10

11

12

13

1

2

3

## FURTHER ENFORCEMENT ACTION

Division 104, Part 12, Chapter 4, (commencing with section 116270) of the California Health and Safety Code authorizes the Division to: issue additional citations with assessment of penalties if the Water System continues to fail to correct a violation identified in a citation; take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with orders of the Division; and petition the superior court to take various enforcement measures against a public water system that has failed to comply with orders of the Division. The Division does not waive any further enforcement action by issuance of this Citation.

15

16

17

18

14

## PARTIES BOUND

This Citation shall apply to and be binding upon the Water System, its officers, directors, agents, employees, contractors, successors, and assignees.

19

20

21

#### SEVERABILITY

The directives of this Citation are severable, and the District shall comply with each and every provision thereof notwithstanding the effectiveness of any other provision.

23

22

24

25

26

27



CITATION NO. 21-14C Issued: August 18, 2014

Reese B. Crenshaw, P.E., District Engineer Valley District

Drinking Water Field Operations Branch

